



AHMEDABAD MUNICIPAL CORPORATION FIRE AND EMERGENCY SERVICES DEPARTMENT

DANAPITH FIRE STATION (HEADQUARTERS), NR.AMC OFFICE, DANAPITH, AHMEDABAD

NOC Number: NOC504914102021

Category: School

NOC Issue Date: 22/10/2021

NO OBJECTION CERTIFICATE

This is to certify that management of M/s ZEBAR SCHOOL FOR CHILDREN located at OPP-SUYOG APARTMENT, B/H COPPER STONE, OFF-THALTEJ SHILAJ ROAD, THALTEJ, AHMEDBAD. has installed necessary Fire Protection Equipments mentioned below.

Hydrant System With

* Main Pump	- (1 Nos.)
* Hose Box with Hose	- (7 Nos.)
* Hydrant Point / Valve	- (7 Nos.)
* Fire Bridge Inlet (2/4 Way)	- (1 Nos.)
* Hose Reel	- (7 Nos.)
* Short Branch	- (7 Nos.)
* Sprinklers System Installed	Yes
* Manual Call Point	- (9 Nos.)
* Fire Alarm System Installed	Yes

Fire Extinguishers

* 6 Kg. Capacity ABC Type	- (17 Nos.)
* 4.5 Kg. Capacity Co2 Type	- (13 Nos.)
* 9 Liter Capacity Water/Co2 Type	- (13 Nos.)

Pranav
Pranav Pandya
Manager - Administration
ZEBAR SCHOOL FOR CHILDREN

All the Fire Protection Equipments installed shall be maintained in working order throughout the validity period of this certificate.

This Certificate is valid for TWO YEAR from the date of issue.

Starnistha Sinha




Rajesh

(Rajesh Bhatt)
Chief Fire Officer (I/c)
Ahmedabad Municipal Corporation